

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switch-Disconnecter
Name and address of the applicant	NOARK Electrics (Shanghai) Co., Ltd. No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China
Name and address of the manufacturer	NOARK Electrics (Shanghai) Co., Ltd. No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China
Name and address of the factory	NOARK Electrics (Shanghai) Co., Ltd. No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	See Annex
Trademark / Brand (if any)	NOARK
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	Ex9ASD40,Ex9ASD40-HU
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2020 in conjunction with IEC 60947-1:2020
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2022CQC-101632


This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Jun.13,2022

Signature:



Xie ZhaoXu

CB 0069323

Ex9ASD40,Ex9ASD40-HU

Uimp: 12kV;

Ui: 1500V;

Ith: 4000A;

Ue: AC380/400/415/440/525/660/690V, AC800/1000V;

Ie: 1600A,2000A,2500A,2900A,3200A,3600A,4000A;

Icw: 85kA/1s(Ex9ASD40), 75kA/1s(Ex9ASD40-HU);

Icm(Peak value): 187kA(Ex9ASD40),165kA(Ex9ASD40-HU);

Utilization category: AC-22A,AC-23A;

Number of poles: 3P,4P;50/60Hz;IP30;

Auxiliary contacts: (AX-21 Certif. No.CN46394)

1NO1NC~12NO12NC;

Ith: 5A;

AC-15:Ue/Ie:AC110V/5A, AC240V/4A, AC415V/2A;


DC-13:Ue/Ie:DC110V/0.25A, DC220V/0.25A

Page 1 of 1

Additional information (if necessary)

Date: Jun.13,2022

Signature:



Xie ZhaoXu