

IEC**IECEE**

Ref. Certif. No.

CN57634-M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Circuit-breakers Incorporating Residual Current Protection

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NXBLE-125,NXBLE-125E,NXBLG-125;

Additional information (if necessary may also be reported on page 2)

The latest CB certificate No. is CN57634-M1, dated 2023-04-24. The issuance of the M2 certificate is to increase product types.

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th Edition);IEC 60947-1:2007;IEC 60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

03601-A-24CB0002-S-M2

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Feb.26,2024

Signature:

Xie ZhaoXu

NXBLE-125,NXBLE-125E,NXB LG-125

Ui:500V; Uimp:4kV;

Ue:AC208V/220V/230V/240V(1P+N,2P),AC208V(3P,3P+N,4P),AC380V/400V/415V(3P,3P+N,4P);

In:63A,80A,100A,125A;

Over-current Release Type:Thermal Magnetic;

Rated frequency:50/60Hz;

Ics=7.5kA,Icu=10kA;

I Δ n:NXBLE-125(Type AC),NXBLE-125E(Type AC),NXB LG-125(Type AC):0.03A,0.05A,0.075A,0.1A,0.3A;

NXBLE-125(Type A),NXBLE-125E(Type A):0.03A,0.1A,0.3A;

I Δ m:2.5kA;

Selectivity Category:A;

Residual current Type:Electronic;

Number of poles:

NXBLE-125,NXBLE-125E:1P+N(1 protected pole with a switched neutral pole),
2P,3P,3P+N(3 protected poles with a switched neutral pole),4P;

NXB LG-125:1P+N(1 protected pole with a switched neutral pole),2P;

1P+N,3P+N:not suitable for isolation,2P,3P,4P suitable for isolation.

Page 1 of 1

Additional information (if necessary)

Date:

Feb.26,2024

Signature:



Xie ZhaoXu