



# CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE220303007589-A1

**Product** Circuit-breaker Incorporating Residual Current Protection

**Applicant** Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

**Type/Model** NXBLE-125,NXBLE-125E,NXBLG-125;

**Technical data** See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 03601-A-24D0004-S, the submitted sample(s) of the above item complies with:

**EN 60947-2:2017/A1:2020;EN 60947-2:2017**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

**Valid from: Feb.26,2024**

**Valid until: Feb.20,2025**

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





# CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE220303007589-A1

NXBLE-125,NXBLE-125E,NXB LG-125

Ui:500V; Uimp:4kV;

Ue:AC208V/220V/230V/240V(1P+N,2P),AC208V(3P,3P+N,4P),AC380V/400V/415V(3P,3P+N,4P);

In:63A,80A,100A,125A;

Over-current Release Type:Thermal Magnetic;

Rated frequency:50/60Hz;

Ics=7.5kA,Icu=10kA;

I $\Delta$ n:NXBLE-125(Type AC),NXBLE-125E(Type AC),NXB LG-125(Type AC):0.03A,0.05A,0.075A,0.1A,0.3A;

NXBLE-125(Type A),NXBLE-125E(Type A):0.03A,0.1A,0.3A;

I $\Delta$ m:2.5kA;

Selectivity Category:A;

Residual current Type:Electronic;

Number of poles:

NXBLE-125,NXBLE-125E:1P+N(1 protected pole with a switched neutral pole),  
2P,3P,3P+N(3 protected poles with a switched neutral pole),4P;

NXB LG-125:1P+N(1 protected pole with a switched neutral pole),2P;

1P+N,3P+N:not suitable for isolation,2P,3P,4P suitable for isolation.



CHINA QUALITY CERTIFICATION CENTRE