



Ref. Certif. No.

SE-110791

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection for household and similar installations (CBOs)

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1 Chint Road, Chint Industrial Zone North Baixiang,
Yueqing, Zhejiang Province, P.R.China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Same as applicant

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See page 2

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NXB-63

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

230101445SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 13 April, 2023



Signature:

Quan Li



Ref. Certif. No.

SE-110791

Rating and principal characteristics

Ue= 220V~, 230V~, 240V~ (1P, 1P+N),
Ue= 380V~, 400V~, 415V~ (2P, 3P, 3P+N, 4P),
In= 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A
B-, C-&D-type, Ics= Icn= 6000A
1P+N and 3P+N with a switched neutral pole

Date: 13 April, 2023

Signature: *AnamLi*